Step	Status	Date (as of)	Annual kWh savings acheive	Ann. MWh run	Total l	Remo	Adde	LED	NonW	% rem	% LE	% NW
Perform Street Light Audit	Complete. 74 lights per Central Hudson surveyed.	Nov 2015			74							
	3 lights in Central Hudson list identified as improperly billed to Town.	Dec 2015		0	71	0	0	0		0.00%	0.00%	
	8 dayburners located and reported (incl. 1 private light). Fixed by Central Hudson	Dec 2015	6544	6.5	71	0	0	0		0.00%	0.00%	
	11 nonworking streetlights located; 3 malfunctiong streetlights located	Dec 2015		6.5	71	0	0	0	16	0.00%	0.00%	22.54
	Malfunctioning streetlights and 4/11 nonfunctional streetlights reported. Fixed by	Dec 2015	-3021	6.5	71	0	0	0	9	0.00%	0.00%	12.68
Review Central Hudson LED offering for dark sky compliance	Reviewed. Compliant.	Dec 2015		6.5	71	0	0	0	9	0.00%	0.00%	12.68
	Replaced two NW 175W lights with 39W LEDs.	Jan 2016	676	7.2	71	0	0	2	7	0.00%	2.82%	9.86%
	Added 1 39W LED at 209 & Tongore.	Feb 2016	-156	7.1	72	0	1	3	7	0.00%	4.17%	9.72%
	$5500 bill credit for improper billing obtained from CH.	March 2016		7.1	72	0	1	3	7	0.00%	4.17%	9.72%
	Light recently out at 209 & Kripplebush. Reported, requested 82W LED.	April 2016		7.1	72	0	1	3	8	0.00%	4.17%	11.11
	Malfunctioning 316W light at 209&Kripplebush CH replaced with 93W LED.	June 2016	892	8.0	72	0	1	4	7	0.00%	5.56%	9.72%
Identify lights for possible reduction	25 lights identified, 7 of which were non-working.	December 2016		8.0	72	0	1	4	7	0.00%	5.56%	9.72%
	Delayed reporting 7 nonworking lights for possible elimination to CH	December 2016	6056	14.0	72	0	1	4	7	0.00%	5.56%	9.72%
Contact Fire dapartments and PD regarding potential light removals	Contacted. 3 working lights taken off possible removal list.	March 2016		14.0	72	0	1	4	7	0.00%	5.56%	9.72%
Send letters to nearby residents requesting opinions on removals	Letters sent	April 2016		14.0	72	0	1	4	7	0.00%	5.56%	9.72%
Collect and analyze responses	Complete.	June 2016		14.0	72	0	1	4	7	0.00%	5.56%	9.72%
Keep lights residents want	2 lights removed from list per feedback	June 2016		14.0	72	0	1	4	7	0.00%	5.56%	9.72%
Remove lights without any opposition to removal	Request sent to Central Hudson.10 lights; 5x175W (1 not working), 3x70W 2x15	July 2016		14.0	72	0	1	4	7	0.00%	5.56%	9.72%
Requested lights removed by CH	pending	August 2016	5764	19.8	62	10	1	4	7	14.08	6.45%	11.29
Hold hearing to discuss 10 possible removals with mixed feedback	pending	September 201										
Request removal for lights identified at hearing	pending	October 2016										