




# 124 Franklin Street, Kingston Solar photovoltaics (PV) Analysis

Megan Day  
Ella Zhou  
Kosol Kiatreungwattana  
James Salasovich  
Jal Desai

# Overview

- Screening for solar photovoltaics (PV) opportunity at 124 Franklin Street, Kingston, NY was performed
- The purpose of this screening is to evaluate the techno-economic viability of on-site PV
- This screening should be treated as an initial step to prioritize and focus additional, in-depth analysis of potential renewable energy projects
- NREL used Aurora Solar to calculate PV system size based on solar access and thereafter used that as an input in System Advisory Model (SAM) to perform the techno-economic analysis

# Grid-Tied PV Array Diagram



# 124 Franklin Street



North Side Front Entrance



South West Side Back View




South East Side Back View


Source: Jimmy Salasovich



# 124 Franklin Street



Source: Google Earth



Source: Aurora Solar

# PV Resource Data

- Hourly weather data for Kingston, NY was used in the analysis (TMY file)
- The average annual solar radiation is 4.63 kWh/m<sup>2</sup>/day
  - US high: Phoenix, AZ = 6.57 kWh/m<sup>2</sup>/day
  - US low: Buffalo, NY = 3.99 kWh/m<sup>2</sup>/day

Month	Solar Radiation ( kWh / m <sup>2</sup> / day )
January	3.09
February	3.89
March	4.65
April	5.46
May	5.91
June	6.03
July	6.26
August	5.80
September	5.09
October	3.84
November	3.09
December	2.47
Annual	4.63

Source: PVWatts

# Net Metering

Incentive Type:	New York (PSL §66-j) - Net Metering*								
Eligible Renewable/ Other Technologies:	Solar			Micro-hydroelectric		Biogas	Micro CHP	Fuel Cell	
Applicable Sectors:	Residential	Non-Residential	Farm Service Solar	Residential	Non-Residential	Farm-Waste & Non-Residential	Residential	Residential	Non-Residential
Limit on System Size:	25 kW	Up to 2 MW	Up to 100 kW	25 kW	Up to 2 MW	1 MW	10 kW	10 kW	Up to 2.0 MW
Remote Net Metering:	No**	Yes	Yes	No**	Yes	Yes	No	No**	Yes
Limit on Overall Enrollment:	6% of 2005 Electric Demand per IOU for Solar, Biogas, Micro CHP, Micro-hydroelectric and Fuel Cells combined								

Incentive Type:	New York (PSL §66-l) - Net Metering*		
Eligible Renewable/ Other Technologies:	Wind		
Applicable Sectors:	Residential	Non-Residential	Farm-Service Wind
Limit on System Size:	25kW	Up to 2 MW	500 kW
Remote Net Metering:	No**	Yes	Yes

<https://programs.dsireusa.org/system/program/detail/453>  
<https://www.cenhud.com/dg/netmetering>

## Financing Scenario Analyzed

- Direct purchase financed with 100% and 0 % debt
  - City-owned
  - City/non-profits are ineligible for federal (and state, if any) tax incentives

## Utility

- Served by Central Hudson Gas and Electric Corp.
- Rates
  - Energy Rate: \$0.13 /kWh



# Technical Assumptions

	Assumption	Source
Technology	System on Rooftop	
Panel Tilt	<ul style="list-style-type: none"> <li>Follow the roof pitch on pitched rooftop</li> </ul>	
Azimuth	Follows roof orientation for pitched roofs	
Degradation Rate	0.5%	SAM default
Total Installed Cost	\$2.70/Wdc	U.S. Solar Photovoltaic System Cost Benchmark: Q1 2018; Ran Fu, David Feldman, and Robert Margolis, <a href="https://www.nrel.gov/docs/fy19osti/72399.pdf">https://www.nrel.gov/docs/fy19osti/72399.pdf</a>
Operations and Maintenance Cost	\$16/kW-yr.	<u>NREL ATB</u>
Weather Data	TMY Hourly Data	TMY hourly data for Kingston, NY
<u>Electricity Escalation Rate</u>	2.5%	Assumed; need to clarify with the utility as well as from past bills [Important parameter which has a major impact on the economics].
Incentives	Not Applicable for Direct Purchase Scenario	
<u>Total system losses</u>	14.08%	SAM Defaults [ would impact solar generation, if changed]

# Financial Assumptions (Direct Purchase Model)


	Assumption	Source
Debt Percentage	100% and 0%	
Loan Term	25 years	
Loan Rate	3%/yr.	
Analysis Period	25 years	
Real Discount Rate	3.0%	Energy Price Indices and Discount Factors for Life-Cycle Cost Analysis – 2018 Annual Supplement to NIST Handbook 135, Priya D. Lavappa Joshua D. Kneifel, <a href="https://nvlpubs.nist.gov/nistpubs/ir/2018/NIST.IR.85-3273-33.pdf">https://nvlpubs.nist.gov/nistpubs/ir/2018/NIST.IR.85-3273-33.pdf</a>
Nominal Discount Rate	2.8%	<a href="https://nvlpubs.nist.gov/nistpubs/ir/2018/NIST.IR.85-3273-33.pdf">https://nvlpubs.nist.gov/nistpubs/ir/2018/NIST.IR.85-3273-33.pdf</a>
Average Inflation Rate	-0.2%	<a href="https://nvlpubs.nist.gov/nistpubs/ir/2018/NIST.IR.85-3273-33.pdf">https://nvlpubs.nist.gov/nistpubs/ir/2018/NIST.IR.85-3273-33.pdf</a>
Federal Income Tax Rate	0%/yr.	Non-profit
State Income Tax Rate	0%/yr.	Non-profit
Sales Tax	0%	Non-profit
Property Tax	0%	City owns site
Cost of Acquiring Financing	\$0	
Construction Financing	None	
Reserve Accounts	None	
Return on Equity	0%	
Federal ITC	0%	
MACRS	No	

# SAM and Aurora Analysis

# Aurora Solar Modeling

- Aurora Solar was used to determine the PV capacity
- PV Inputs:
  - 90 % minimum annual solar access
  - Landscape panel orientation
  - Tilt: Roof pitch
- PV Capacity : 4.1 kW


<https://www.aurorasolar.com/>





# System Advisor Model (SAM)

Free software that combines detailed performance and financial models to estimate the cost of energy for systems



<http://sam.nrel.gov/download>

## Technologies

- Photovoltaics, detailed & PVWatts
- Battery storage
- Concentrating solar power
- Wind
- Geothermal
- Biomass
- Solar water heating

## Financials

- Behind-the-meter
- residential
- commercial
- Power purchase agreements
- single owner
- equity flips
- sale-leaseback
- Simple LCOE calculator

# SAM Results

# SAM Analysis Results –Direct Purchase with 100 % Debt

Option 1: Central Air Conditioner	
Metric	124 Franklin Street
Type	Roof mount
PV Size (kW)	4.1
PV System Annual Energy Production Year 1 (kWh)	4,815
Annual Site Load, (MMBTU/yr.)	50.9
Annual Site Load (kWh)	14,913
Percent Load Met by PV System Year 1 (%)	32%
Levelized COE Nominal (cents/kWh)	15.32
Net Capital Cost (\$)	11,070
Loan Percent (%)	100%
Net Present Value (\$)	\$1,090
Simple Payback (years)	16.8

Comes from BEopt Results  
(See Appendix)

Option 2: Mini-Split Heat Pump	
Metric	124 Franklin Street
Type	Roof mount
PV Size (kW)	4.1
PV System Annual Energy Production Year 1 (kWh)	4,815
Annual Site Load, (MMBTU/yr.)	27.5
Annual Site Load (kWh)	8,057
Percent Load Met by PV System Year 1 (%)	60%
Levelized COE Nominal (cents/kWh)	15.32
Net Capital Cost (\$)	11,070
Loan Percent (%)	100%
Net Present Value (\$)	\$1,090
Simple Payback (years)	16.8

1 MMBTU = 292.9974 kWh <https://business.directenergy.com/understanding-energy/energy-tools/conversion-factors>

Buy Rate = Sell Rate (\$0.13/kWh)

# SAM Analysis Results –Direct Purchase with 0 % Debt

Option 1: Central Air Conditioner	
Metric	124 Franklin Street
Type	Roof mount
PV Size (kW)	4.1
PV System Annual Energy Production Year 1 (kWh)	4,815
Annual Site Load, (MMBTU/yr.)	50.9
Annual Site Load (kWh)	14,913
Percent Load Met by PV System Year 1 (%)	32%
Levelized COE Nominal (cents/kWh)	15.00
Net Capital Cost (\$)	11,070
Loan Percent (%)	0%
Net Present Value (\$)	\$1,349
Simple Payback (years)	16.8

Comes from BEopt Results  
(See Appendix)

Option 2: Mini-Split Heat Pump	
Metric	124 Franklin Street
Type	Roof mount
PV Size (kW)	4.1
PV System Annual Energy Production Year 1 (kWh)	4,815
Annual Site Load, (MMBTU/yr.)	27.5
Annual Site Load (kWh)	8,057
Percent Load Met by PV System Year 1 (%)	60%
Levelized COE Nominal (cents/kWh)	15.00
Net Capital Cost (\$)	11,070
Loan Percent (%)	0%
Net Present Value (\$)	\$1,349
Simple Payback (years)	16.8

1 MMBTU = 292.9974 kWh <https://business.directenergy.com/understanding-energy/energy-tools/conversion-factors>

Buy Rate = Sell Rate (\$0.13/kWh)



## Parametric Analysis Option 1: Central Air Conditioner (100% Debt)

Variables	Inputs Varied			Outputs	
	PV Installed Cost \$/W	Loan Rate	Electricity Escalation Rate	NPV(\$)	Simple Payback Period (yrs.)
PV Installed Cost	2	3%	2.50%	4,027	13.0
PV Installed Cost	2.50	3%	2.50%	1,930	15.7
PV Installed Cost	2.70	3%	2.50%	1,090	16.8
PV Installed Cost	3	3%	2.50%	-168	18.4
PV Installed Cost	3.5	3%	2.50%	-2,266	20.9
Loan Rate	2.70	1.50%	2.50%	2,898	16.8
Loan Rate	2.70	2%	2.50%	2,314	16.8
Loan Rate	2.70	2.50%	2.50%	1,712	16.8
Loan Rate	2.70	5%	2.50%	-1,577	16.8
Loan Rate	2.70	6%	2.50%	-3,012	16.8
Electricity Escalation Rate	2.70	3%	0%	-2,103	21.3
Electricity Escalation Rate	2.70	3%	1%	-962	19.1
Electricity Escalation Rate	2.70	3%	1.50%	-326	18.2
Electricity Escalation Rate	2.70	3%	2%	355	17.5
Electricity Escalation Rate	2.70	3%	3%	1,880	16.2

- PV installed cost, the loan rate, and annual electricity cost escalation rate assumptions have a large impact on net present value (NPV)
- Lowering the PV installed cost and increasing the electricity cost escalation rate lowers the simple payback period
- The loan rate does not affect the simple payback, which only considers the installed cost and the value of the electricity generated

## Parametric Analysis Option 2: Mini-Split Heat Pump (0% Debt)

Variables	Inputs Varied		Outputs	
	PV Installed Cost \$/W	Electricity Escalation Rate	NPV(\$)	Simple Payback Period (yrs.)
PV Installed Cost	2	2.50%	4,219	13.0
PV Installed Cost	2.50	2.50%	2,169	15.7
PV Installed Cost	2.70	2.50%	1,349	16.8
PV Installed Cost	3	2.50%	119	18.4
PV Installed Cost	3.5	2.50%	-1,931	20.9
Electricity Escalation Rate	2.70	0%	-1,845	21.3
Electricity Escalation Rate	2.70	1%	-703	19.1
Electricity Escalation Rate	2.70	1.50%	-68	18.2
Electricity Escalation Rate	2.70	2%	614	17.5
Electricity Escalation Rate	2.70	3%	2,139	16.2

- PV installed cost and annual electricity cost escalation rate have a large impact on NPV
- Lowering the PV installed cost and increasing the annual electricity cost escalation rate lowers the simple payback period

# Key Takeaways

- 4.1 kW of roof mount PV system can be installed at 124 Franklin Street
- Option 1 (Central Air Conditioner): 32% of the load (estimated total building electricity and natural gas consumption) can be met by the proposed PV system (Year 1)
- Option 2 (Mini-Split Heat Pumps): 60% of the load (estimated electricity consumption with no natural gas consumption) can be met by the proposed PV system (Year 1)
- Two scenarios were evaluated, one with 100% debt and other with 0% debt
- Net present value (NPV) of 0% debt scenario is more positive than 100% debt scenario's NPV while the simple payback period remains same
- Parametric analysis was performed on various on various parameters
  - Option 1 (Central Air Conditioner) with 100% debt
    - If the installed PV cost is 3.0 \$/Wdc or above, or if the loan rate is 5% or above, or electricity escalation rate is less than 1.5%, while other parameters remain the same, the NPV would be negative and installing PV solar would not be economically favorable.
  - Option 2 (Mini-Split Heat Pumps) with 0% debt
    - If the installed PV cost is above 3.0 \$/Wdc or electricity cost escalation rate is less than 1.5%, while other parameters remain the same, the NPV would be negative and installing PV solar would not be economically favorable.

## Contact Information:

Jal Desai

[Jal.Desai@nrel.gov](mailto:Jal.Desai@nrel.gov)

[www.nrel.gov](http://www.nrel.gov)





NREL is a national laboratory of the U.S. Department of Energy, Office of Energy Efficiency and Renewable Energy, operated by the Alliance for Sustainable Energy, LLC.



# Appendix

# HVAC Types



# Measures

124 Franklin Street			
Parametric Case:	Baseline/Existing Conditions	Option 1: Mini-Split Heat Pumps for Space Cooling and Heating	Option 2: Air Conditioner with Natural Gas Furnace
Number of Stories:	2	2	2
Wall Insulation:	None	R-23 Closed Cell Spray Foam	R-23 Closed Cell Spray Foam
Attic Insulation:	R-13 loose fiberglass	Ceiling R-60 Cellulose	Ceiling R-60 Cellulose
Basement Insulation:	None	Ceiling R-30 Closed Cell Spray	Ceiling R-30 Closed Cell Spray
Windows:	Single pane	Low-E, Double, Non-metal, Air,M-Gain	Low-E, Double, Non-metal, Air,M-Gain
Doors:	Wood	Fiberglass	Fiberglass
Air Leakage:	1.7 ACH	0.07 ACH	0.07 ACH
HVAC Heating:	Coal stove and 2x fireplaces	Mini-Split Heat Pumps 9kBtuh/unit - SEER 33, 14.2 HSPF	Furnance, Gas 92.5 % AFUE
HVAC Cooling:	There was no space cooling in existing building but SEER 14 space cooling was assumed so that a comparison could be made between the parametric options	Mini-Split Heat Pumps 9kBtuh/unit - SEER 33, 14.2 HSPF	Air Conditioner SEER 24.5
HVAC Ducts:	Uninsulated	n/a	7.5 % Leakage,R-8
Water Heating:	80% efficient natural gas	Electric Tankless	Electric Tankless
Water Heating Distribution:	Not insulated	R-2, Trunch Branch, Copper	R-2, Trunch Branch, Copper
Lighting:	100% Incandescent lights	100 % LED lights	100 % LED lights
Plug Loads:	Standard efficiency, but note the building was empty but standard appliances with an equipment power density of 1.0 Watts per sq ft. are assumed for the baseline so that a comparison could be made between the parametric options	0.5 Watts per sq ft.	0.5 Watts per sq ft.

# Disclaimer

This document was prepared as an account of work sponsored by an agency of the United States government. Neither the United States government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States government or any agency thereof.

- The analysis is based on projections, estimates or assumptions made on a best-effort basis, based upon expectations of current and future conditions at the time they were developed.
- The analysis was prepared with information available at the time the analysis was conducted. Analysis results could be different if new information becomes available and is incorporated.
- This analysis relies on site information provided to NREL that has not been independently validated by NREL.